



Lee's Summit R-VII School District  
Purchasing and Distribution Services  
702 SE 291 Highway  
Lee's Summit, MO 64063  
816-986-2420  
Email: [bruce.gibson@lsr7.net](mailto:bruce.gibson@lsr7.net)

## **ADDENDUM #2**

**DATE: March 20, 2017**  
**TO: All Bid Recipients**  
**FROM: Bruce Gibson, Assistant Director of Facilities**  
**RE: Bid #2017-07 HVAC Units Replacements – LSE**

The Lee's Summit R-7 School District is issuing an Addendum to provide all interested bidders with the information below.

- 1. Existing Condensing Unit's Support on Roof – Reuse or New Equipment Rails?*  
A question was asked about the existing condensing units on the roof and if the existing supports could be reused or if new equipment rails were required? Please reuse the existing supports. If the existing supports are found to be in poor condition please contact the Districts representative and the District will furnish new.
- 2. Existing Refrigerant Lines – Are they OK to Reuse?*  
A question was asked about the existing refrigerant lines serving the five existing split systems in regard to their reuse with the new equipment. The existing refrigerant lines may be reused provided they meet the capacity requirements of the new split systems, have no traps, and are properly flushed.

**Please note that the Bid closing date has changed to March 24th, 2017 at 2:00 pm, CDT.**

**THE UNDERSIGNED HEREBY:**

Certifies that he/she is an authorized agent of said company and has the authority to legally enter into a binding Service Agreement. This entire Addendum and all attachments must be submitted with the Bid by the deadline, March 24th, 2017 at 2:00 pm, CDT.

**ADDENDUM #2 TO BID #2017-07 HVAC Units Replacement**

\_\_\_\_\_  
Name of Vendor Authorized Representative (Print)

\_\_\_\_\_  
Street Address Authorized Signature

\_\_\_\_\_  
City State, Zip Code

\_\_\_\_\_  
Telephone Contact Email